

The price for the repairs requested at the jail is \$19,405.

This includes the following:

- 1-Clean chilled water strainers and condenser coils on chillers 2 and 3 on the roof of the jail
- 2-Replace control and display board on chiller 3 on the roof of the jail
- 3-Install by-pass line and valve in pump piping in the 2nd floor mechanical room of the jail
- 4-Replace damaged pump piping insulation in the 2nd and 3rd floor mechanical rooms of the jail

Please let me know if you would like to move forward with the first two items. We can utilize a portion of the project contingency to fund this.

Let me know if you have any questions.

Thanks,
Chase

Chase Raska

Sr. Project Manager
Energy & Sustainability Services
Schneider Electric

D +1 (832) 309 1584
E chase.raska@schneider-electric.com

1650 W. Crosby
Carrollton, TX
75006

